

TYPE	SIZE AWG	NO.OF CONDUCTO RS	CONDUCTORS		INSULATION		JACKET	
			CROSS SECTION mm ²	STRANDS/m m	THICKNESS AVE mm	O.D mm	THICKNESS AVE mm	O.D mm
SVT	18	2	0.836↓	(41/0.158)	0.38	2.03	0.76	5.7
		3	0.836↓	(41/0.158)	0.38	2.03	0.76	6.3
	16	2	1.34↓	(65/0.158)	0.38	2.27	0.76	6.27
		3	1.34↓	(65/0.158)	0.38	2.27	0.76	6.65

TYPE	SIZE AWG	NO.OF CONDUCTO RS	CONDUCTORS		INSULATION		JACKET	
			CROSS SECTION mm ²	STRANDS/m m	THICKNESS AVE mm	O.D mm	THICKNESS AVE mm	O.D mm
SJT SJTW SJTO SJTOW SJTEOW	18	2	0.836↓	(41/0.158)	0.76	2.68	0.76	7.16
		3	0.836↓	(41/0.158)	0.76	2.68	0.76	7.67
	16	2	1.34↓	(65/0.158)	0.76	2.87	0.76	7.8
		3	1.34↓	(65/0.158)	0.76	2.87	0.76	8.3
	14	3	2.12↓	(41/0.251)	0.76	3.26	0.76	9.19
		4	2.12↓	(41/0.251)	0.76	3.26	0.76	9.96
	12	3	3.37↓	(65/0.251)	0.76	3.75	1.14	10.9
	10	3	5.36↓	(105/0.251)	1.14	5.03	1.52	14.5